



Aldersgate Data - Finished Water Entering Salem's Drinking Water System

Sample Date	Microcystin				Cylindrospermopsin				Is there an advisory?	
	<u>Lab Reported</u>	Minimum Reporting Level ²	Health Advisory Level	Vulnerable Population (µg/L)	All Population (µg/L)	<u>Lab Reported</u>	Minimum Reporting Level ²	Health Advisory Level		
		Concentration ¹ (µg/L)	(µg/L)				Concentration ¹ (µg/L)	Vulnerable Population (µg/L)		
4/4/2019	Below Detection Limit	0.15	0.3	1.6	1.6	Below Detection Limit	0.05	0.7	3.0	No
4/9/2019	Below Detection Limit	0.15	0.3	1.6	1.6	Below Detection Limit	0.05	0.7	3.0	No
4/17/2019	Below Detection Limit	0.15	0.3	1.6	1.6	Below Detection Limit	0.05	0.7	3.0	No
4/23/2019	Below Detection Limit	0.15	0.3	1.6	1.6	Below Detection Limit	0.05	0.7	3.0	No
4/30/2019	Below Detection Limit	0.15	0.3	1.6	1.6	Below Detection Limit	0.05	0.7	3.0	No

¹The Lab Reported Concentration is a non-detect when the data concentration is less than the minimum reporting level. The unit µg/L is the same as micrograms per liter of water.

²The Minimum Reporting Level (RL)—is the lowest concentration at which an analyte - Microcystin or Cylindrospermopsin - can be detected in a sample and its concentration can be reported with a reasonable degree of accuracy and precision.



For more about cyanotoxins and drinking water advisories in Salem, visit: <https://cityofsalem.net/water-advisory>

