


## Intake Data - Raw River Water Entering the Geren Island Water Treatment Facility

<b>Sample Date</b>	<b>Microcystin</b>		<b>Cylindrospermopsin</b>		<b>Laboratory</b>
	<i>Lab Reported Concentration</i> <sup>1</sup>	<i>Minimum Reporting Level</i> <sup>2</sup> (µg/L)	<i>Lab Reported Concentration</i> <sup>1</sup>	<i>Minimum Reporting Level</i> <sup>2</sup> (µg/L)	
8/2/2023	Not Detected	0.3	Not Detected	0.2	Willow Lake
8/4/2023	Not Detected	0.3	Not Detected	0.2	Willow Lake


<sup>1</sup>The Lab Reported Concentration is a non-detect when the data concentration is less than the minimum reporting level. The unit µg/L is the same as micrograms per liter of water.

<sup>2</sup>The Minimum Reporting Level (RL)—is the lowest concentration at which an analyte - Total Microcystin or Cylindrospermopsin - can be detected in a sample and its concentration can be reported with a reasonable degree of accuracy and precision.

### Intake - Total Microcystin



### Intake - Cylindrospermopsin



For more about cyanotoxins and drinking water advisories in Salem, visit: <https://cityofsalem.net/water-advisory>