



## Intake Data - Raw River Water Entering the Geren Island Water Treatment Facility

Sample Date	Microcystin		Cylindrospermopsin		Laboratory
	Lab Reported Concentration <sup>1</sup>	Minimum Reporting Level <sup>2</sup> (µg/L)	Lab Reported Concentration <sup>1</sup>	Minimum Reporting Level <sup>2</sup> (µg/L)	
5/6/2024	Non Detect at MRL	0.2	Non Detect at MRL	0.2	Willow Lake
5/13/2024	Non Detect at MRL	0.2	Non Detect at MRL	0.2	Willow Lake
5/21/2024	Non Detect at MRL	0.2	Non Detect at MRL	0.2	Willow Lake
5/27/2024	Non Detect at MRL	0.2	Non Detect at MRL	0.2	Willow Lake
5/28/2024	Non Detect at MRL	0.2	Non Detect at MRL	0.2	Willow Lake

<sup>1</sup>The Lab Reported Concentration is a non-detect when the data concentration is less than the minimum reporting level. The unit µg/L is the same as micrograms per liter of water.

<sup>2</sup>The Minimum Reporting Level (MRL)—is the lowest concentration at which an analyte - Total Microcystin or Cylindrospermopsin - can be detected in a sample and its concentration can be reported with a reasonable degree of accuracy and precision.



For more about cyanotoxins and drinking water advisories in Salem, visit: <https://www.cityofsalem.net/community/household/water-utilities/salem-s-drinking-water>